


VOC emission

Decospan NV
Lageweg 33
8930 Menen
Belgium

Attestation

Sample name	Shinnoki_MDF_Oak
Batch no.	P022-28608
Date of production	12/10/2022
Product type	Decorative veneered MDF, varnished
Sample reception	13/10/2022
Attestation date	4/05/2023

This attestation confirms compliance with the following VOC requirements on low emitting regulations, standards or protocols:

Regulation or protocol	Conclusion	Version of regulation of protocol
French VOC regulations		Arrêté du 28 mai 2009 modifiant l'arrêté du 30 avril 2009, Arrêté du 20 février 2012 modifiant l'arrêté du 19 avril 2011, Décret no 2011-321 du 23 mars 2011
Italian regulation (public procurement)	Pass	Decree 11 October 2017 (GU n.259 - 6-11-2017)
BREEAM International	Pass/Acceptance	BREEAM International New Construction 2021 v6.0
BREEAM Norway	Pass/Acceptance	BREEAM-NOR 2022 v6.0 : New Construction technical manual SD5076NOR – Ver : 6.0
BREEAM NL	Pass/Acceptance	BREEAM-NL Nieuwbouw 2020 v1.0
E1	Pass	E1 (Formaldehyde emission): Limit $E1 \leq 124 \mu\text{g}/\text{m}^3$

Full details on the testing and direct comparison with limit values are available in SPT2023-R110. For reporting statements of conformity (decision rule) the measurement uncertainty is not taken into account. Testing was performed according to the latest versions of EN 16516 and ISO 16000 series by ISO/IEC 17025 accredited test laboratory Normec Product Testing.



M. Lor
Managing Director Normec Product Testing

Test results are only valid for the tested sample(s), as received from the client. Test report may only be copied or reprinted in this entity, parts of it only with a written acceptance by Normec Product Testing.

SPT2023-R110